

City of Santa Clara

Building Division
1500 Warburton Ave.
Santa Clara, CA 95050
www.santaclaraca.gov

Building Division: 408-615-2440

Email: Building@santaclaraca.gov

Permit Center: 408-615-2420

Email: PermitCenter@santaclaraca.gov

Automated Inspection Scheduling System: 408-615-2400

2016 CALIFORNIA GREEN BUILDING CODE (CGC) CHECKLIST FOR ADDITIONS OR ALTERATIONS TO (E) NONRESIDENTIAL BUILDINGS

Building additions of 1000 square feet or greater AND/OR building alterations with a permit valuation of \$200,000 or more shall be designed to include the green building measures specified as mandatory in the application checklists for additions or alterations.

BUILDING PERMIT NO.: BLD20

ADDRESS:

**MANDATORY
MEASURES
SPECIFIED**
(Please check
boxes below)

Feature or Measure	Yes
SITE DEVELOPMENT (5.106)	
Storm water pollution control. Newly additions which disturb less than one acre of land shall prevent the pollution of storm water runoff from the construction activities through local ordinance per CGC 5.106.1.1 or Best Management Practice (BMP) per CGC 5.106.1.2.	<input type="checkbox"/>
Short-Term bicycle parking. If an addition or alteration that add 10 or more visitor vehicular parking spaces, provide permanently anchored bicycle racks within 200 feet of the visitors' entrance, readily visible to passers-by, for 5 percent of visitor motorized vehicle parking capacity, with a minimum of one two-bike capacity rack per CGC 5.106.4.1.	<input type="checkbox"/>
Long-Term bicycle parking. For additions or alterations that add 10 or more tenant vehicular parking space, provide secure bicycle parking for 5 percent of tenant-occupied motorized vehicle parking capacity, with a minimum of one space per CGC 5.106.4.2.	<input type="checkbox"/>
Designated parking for clean air vehicles. In additions or alterations that add 10 or more vehicular parking spaces, provide designated parking for any combination of low-emitting, fuel-efficient and carpool/van pool vehicles as shown in Table 5.106.5.2. Parking stall marking shall comply with CGC 5.106.5.2.	<input type="checkbox"/>
Grading and paving. For additions and alterations that alter the drainage path, construction plans shall indicate how site grading or a drainage system will manage all surface water flows to keep water from entering buildings. Examples of methods to manage surface water include those shown in Items 1-5 per CGC 5.106.10.	<input type="checkbox"/>
WATER EFFICIENCY AND CONSERVATION	
INDOOR WATER USE (CGC 5.303)	
Meters. Separate submeters or metering devices shall be installed for the uses described in Sections 503.1.1 and 503.1.2.	
Additions in excess of 50,000 square feet. Separate submeters shall be installed as follows:	
1. For each individual leased, rented or other tenant space within the building projected to consume more than 100 gal/day, including but not limited to, spaces used for laundry or cleaner, restaurant for food service, medical or dental office, laboratory or beauty salon or barber shop.	<input type="checkbox"/>
2. Where separate submeters for individual building tenants are unfeasible, for water supplied to the following subsystem:	<input type="checkbox"/>
a. Makeup water for cooling towers where flow through is greater than 500 gpm.	
b. Makeup water for evaporative coolers greater than 6 gpm.	
c. Steam and hot-water boilers with energy input more than 500,000 Btu/h.	
Excess consumption. A separate submeter or metering device shall be provided for any tenant within an addition that is projected to consume more than 1,000 gal/day.	<input type="checkbox"/>
Water conserving plumbing fixtures and fittings. New plumbing fixtures (water closets and urinals) and fittings (faucets and showerheads) in additions or areas of alterations shall comply with the prescriptive reduced flow rates specified in CGC 5.303.3.1 through 5.303.3.3.	<input type="checkbox"/>

Commercial kitchen equipment. Food waste disposers. New disposers in additions and areas of alteration shall either modulate the use of water to no more than 1 gpm when the disposer is not in use (not actively grinding food waste/no-load) or shall automatically shut off after no more than 10 minutes of inactivity. Disposers shall use no more than 8 gpm of water per CGC 5.303.4.1.	<input type="checkbox"/>
Standards for plumbing fixtures and fittings. Plumbing fixtures and fittings shall meet the applicable standards referenced in Table 1701.1 of the 2016 <i>California Plumbing Code</i> and in Chapter 6 of CGC.	<input type="checkbox"/>
OUTDOOR WATER USE (CGC 5.304)	
Outdoor water use in landscape areas equal to or greater than 500 square feet: shall comply with CGC 5.304.2.	<input type="checkbox"/>
Outdoor water use in rehabilitated landscape projects equal to or greater than 2500 square feet: shall comply with CGC 5.304.3.	<input type="checkbox"/>
Outdoor water use in landscape area of 2500 square feet or less: shall comply with CGC 5.304.4.	<input type="checkbox"/>
Graywater or rainwater use in landscape areas: shall comply with CGC 5.304.5.	<input type="checkbox"/>
WEATHER RESISTANCE AND MOISTURE MANAGEMENT (CGC 5.407)	
Weather protection. Provide a weather-resistant exterior wall and foundation envelope as required by <i>California Building Code</i> Section 1403.2 and <i>California Energy Code</i> Section 150, manufacturer's installation instructions or local ordinance, whichever is more stringent per CGC 5.407.1.	<input type="checkbox"/>
Moisture control. Employ moisture control measures by the following methods:	
Sprinklers. Prevent irrigation spray on structures per CGC 5.407.2.1.	<input type="checkbox"/>
Entries and openings. Design exterior entries and openings to prevent water intrusion into buildings per CGC 5.407.2.2.	<input type="checkbox"/>
CONSTRUCTION WASTE REDUCTION, DISPOSAL AND RECYCLING (CGC 5.408)	
Construction waste diversion. Recycle and/or salvage for reuse a minimum of 65% of the non-hazardous construction and demolition waste in accordance with Section 5.408.1.1, 5.408.1.2 or 5.408.1.3; or meet a local construction and demolition waste management ordinance, whichever is more stringent (CGC 5.408.1).	<input type="checkbox"/>
Verification of compliance. A copy of the completed waste management report shall be provided per CGC 5.408.1.4.	<input type="checkbox"/>
Excavated soil and land clearing debris. 100% of trees, stumps, rocks, and associated vegetation and soils resulting primarily from land clearing shall be reused or recycle per CGC 5.408.3.	<input type="checkbox"/>
BUILDING MAINTENANCE AND OPERATION (CGC 5.410)	
Recycling by occupants. Provide readily accessible areas that serve the entire building and are identified for the depositing, storage and collection of nonhazardous materials for recycling per CGC 5.410.1.	<input type="checkbox"/>
Addition. All additions conducted within a 12-month period under single or multiple permits, resulting in an increase of 30% or more in floor area, shall provide recycling areas on site.	
Testing and adjusting. Testing and adjusting of systems shall be required for new system to serve an addition or alteration per CGC 5.410.4.	<input type="checkbox"/>
Testing and adjustment report. After completion of testing, adjusting and balancing, provide final report of testing signed by the individual responsible for performing these services per CGC 5.410.4.4.	<input type="checkbox"/>
Operation and maintenance manual. Provide the building owner with detailed operating and maintenance instructions and copies of guaranties/warranties for each system prior to final inspection per CBC 5.410.4.5.	<input type="checkbox"/>
Inspections and reports. Include a copy of all inspection verifications and reports required by the enforcing agency per CGC 5.410.4.5.1.	<input type="checkbox"/>

ENVIRONMENTAL QUALITY	
FIREPLACES (CGC 5.503)	
Install only a direct-vent sealed-combustion gas or sealed wood-burning fireplace, or a sealed woodstove or pellet stove, and refer to residential requirements in the <i>California Energy Code</i> , Title 24, Part 6, Subchapter 7, Section 150.	<input type="checkbox"/>
Woodstoves. Woodstoves and pellet stoves shall comply with US EPA New Source Performance Standards (NSPS) emission limits, where applicable, and shall have a permanent label indicating they are certified to meet the emission limits per CGC 5.503.1.1	
POLUTANT CONTROL (CGC 5.504)	
Temporary ventilation. The permanent HVAC system shall only be used during construction if necessary to condition the area of addition or alteration within the required temperature range for material and equipment installation. If the HVAC system is used during construction, use return air filters with a MERV of 8, based on ASHRAE 52.2-1999, or an average efficiency of 30% based on ASHRAE 52.1-1992. Replace all filters immediately prior to occupancy (CGC 5.504.1)	<input type="checkbox"/>
Covering of duct openings and protection of mechanical equipment during construction. At the time of rough installation or during storage on the construction site and until final startup of the heating, cooling and ventilating equipment, all duct and other related air distribution component openings shall be covered with tape, plastic, sheet metal or other methods acceptable to the enforcing agency to reduce the amount of dust or debris which enter in the system per CGC 5.504.3.	<input type="checkbox"/>
Finish material pollutant control. Finish materials shall comply with Sections 5.504.4.1 through 5.504.4.6. Adhesives, sealants and caulks. Adhesives, sealants and caulks used on the project shall meet the requirements of the standards listed in CGC 5.504.4.1. Paints and coatings. Architectural paints and coatings shall comply with Table 5.504.4.3 unless more stringent local limits apply. Verification. Verification of compliance with this section shall be provided at the request of the enforcing agency per CGC 5.504.4.3.2. Carpet systems. All carpet installed in the building interior shall meet the testing and product requirements of one of the standards listed in Section 5.504.4.4. Composite wood products. Hardwood plywood, particleboard and medium density fiberboard composite wood products used on the interior or exterior of the building shall meet the requirements for formaldehyde as specified in Table 5.504.4.5. Verification. Verification of compliance with this section shall be provided by the enforcing agency per CGC 5.504.4.5.3. Resilient flooring systems. For 80% of floor area receiving resilient flooring, install resilient flooring shall comply with CGC 5.504.4.6. Verification. Documentation shall be provided verifying that resilient flooring materials meet the pollutant emission limits per CGC 5.504.4.6.1.	<input type="checkbox"/>
Filters. In mechanically ventilated buildings, provide regularly occupied areas of the building with air filtration media for outside and return air prior to occupancy that provides at least a MERV of 8. MERV 8 filters shall be installed after any flushed-out or testing and prior to occupancy, and recommendations for maintenance with filters of the same value shall be included in the operation and maintenance manual per CBC 5.504.5.3.	<input type="checkbox"/>
Environmental tobacco smoke (ETS) control. Prohibit smoking within 25 feet of building entries, outdoor air intakes and operable windows where outdoor areas are provided for smoking and within the building as already prohibited by other laws, regulations or policies, whichever are more stringent, per CGC 5.504.7.	<input type="checkbox"/>
INDOOR MOISTURE CONTROL (CGC 5.505)	
Indoor moisture control. Building shall meet or exceed the provisions of California Building Code, CCR, Title 24, Part 2, Section 1203 and Chapter 14.1. (CGC 5.505.1)	<input type="checkbox"/>

AIR QUALITY AND EXHAUST (CGC 5.506)	
Outside air delivery. For mechanically or naturally ventilated spaces in buildings, meet the minimum requirement of Section 120.1 of the California Energy Code and Chapter 4 if CCR, Title 8 or the applicable local code, whichever is more stringent, per CGC 5.506.1.	<input type="checkbox"/>
Carbon dioxide (CO₂) monitoring. For buildings equipped with demand control ventilation, CO ₂ sensors and ventilation controls shall be specified and installed in accordance with the requirements of the California Energy Code, CCR, Section 120(c)(4), per CGC 5.506.2.	<input type="checkbox"/>
ENVIRONMENTAL COMFORT (CGC 5.507)	
Acoustical control. Employ building assemblies and components with STC values determined in accordance with ASTM E90 and ASTM E413 or OITC determined in accordance with ASTM E 1332, using either the prescriptive or performance method in Sections 5.507.4.1 or 5.507.4.2.	<input type="checkbox"/>
Interior sound transmission. Wall and floor-ceiling assemblies separating tenant spaces and tenant spaces and public spaces shall have an STC of at least 40 (CGC 5.507.4.3).	<input type="checkbox"/>
OUTDOOR AIR QUALITY (CGC 5.508)	
Ozone depletion and greenhouse gas reductions. Installation of HVAC, refrigeration and fire suppression equipment shall comply with Sections 5.508.1.1 or 5.508.1.2.	<input type="checkbox"/> As applicable
Supermarket refrigerant leak reduction. New commercial refrigeration systems shall comply with Section 5.508.2 when installed in retail food stores 8,000 square feet or more condition area, and that utilize either refrigerated display cases, or walk-in coolers or freezers connected to remote compressor units or condensing units. The leak reduction measures apply to refrigeration systems containing high-global-warming potential (high-GWP) refrigerants with a GWP of 150 or greater.	<input type="checkbox"/> As applicable

Responsible Designer's Declaration Statement			Contractor Declaration Statement		
I hereby certify that this project has been designed to meet the requirements of the 2016 California Green Building Standards Code.			I hereby certify, as the builder or installer under permit listed herein, that this project will be constructed to meet the requirements of the California Green Building Standards Code.		
Name:			Name:		
Signature:			Signature:		
Date:			Date:		
Company:			License:		
Address:			Address:		
City:	State:	Zip:	City:	State:	Zip: